



Contribution ID: 143

Type: **Sectional**

Control system of the superconducting magnets cryogenic test bench for the NICA accelerator complex

Thursday 28 September 2017 15:30 (15 minutes)

Control system of the superconducting magnets cryogenic test bench has been designed in Tango Controls format. It includes the Thermometry system and the Satellite refrigerators control system. The report describes hardware and software modules for data acquisition and management, archiving system, configuration system, access control system, web service and web client applications.

Author: Mr SEDYKH, Georgy (JINR)

Co-authors: Mr KIRICHENKO, Aleksandr (JINR); GALIMOV, Artem (Joint Institute for Nuclear Research); Mr NEAPOLITANSKIY, Denis (JINR); Mr NIKIFOROV, Dmitriy (JINR); Mr GORBACHEV, Evgeny (VBLHEP JINR); Mr PIVIN, Roman (JINR); Mr VOLKOV, Valery (JINR); Mr KOSACHEV, Viacheslav (JINR)

Presenter: Mr SEDYKH, Georgy (JINR)

Session Classification: Triggering, Data Acquisition, Control Systems

Track Classification: Triggering, Data Acquisition, Control Systems